




DELHI JAL BOARD
(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
WATER TREATMENT PLANT NANGLOI , DELHI-110041




Water samples collected from "Baldev International School" Khasra No. 26/19/1(4-16) Mani Mubarakpur Road, Inder Enclave, New Delhi-110086

Vide challan no. 73 dated 15-06-2024

**THE TEST REPORT IS
FOR THIS PARTICULAR
WATER SAMPLE ONLY.**

S. No	Parameter	Units	Limit		S1
			Acceptable	Permissible	
PHYSICAL EXAMINATION					
1.	Date of collection	-----	--	--	19.06.2024
2.	Date of Analysis	-----	--	--	21.06.2024
3.	Colour	C.U	5.0	15	Clear
4.	Odour	-----	No. Objectionable		N/O
5.	Turbidity	N.T.U.	1.0	5.0	1.2
6.	PH value	-----	6.5	8.5	7.2
7.	Electrical Conductivity	µmho	--	--	218.2
8.	Total dissolved solids	mg/l	500	2000	141.8
CHEMICAL EXAMINATION					
9.	P th Alkalinity	mg/l	--	--	NIL
10.	Total Alkalinity	mg/l	200	600	64
11.	Total Hardness	mg/l	200	600	88
12.	Calcium Hardness	mg/l	--	--	56
13.	Magnesium Hardness	mg/l	--	--	32
14.	Calcium as Ca	mg/l	75	200	22.4
15.	Magnesium as Mg	mg/l	30	100	7.68
16.	Ammonia as N	mg/l	0.5	N.R.	NIL
17.	Nitrite as N	mg/l	---	--	NIL
18.	Nitrate as NO ₃	mg/l	45	N.R.	-
19.	Sulphate	mg/l	200	400	08
20.	Chloride	mg/l	250	1000	14
21.	Dissolved Iron	mg/l	1.0	N.R.	0.02
22.	Fluoride	mg/l	1	1.5	0.08
23.	Cyanide	mg/l	0.05	N.R.	ND
24.	Residual Chlorine	mg/l	0.20 (Min)	1.0	NIL
BACTERIOLOGICAL EXAMINATION					
25.	Coli-form per 100 ml at 37°C	MPN	0		0

REMARKS: As per tested parameters Sample -S1 can be used for drinking purpose.


ACWA
Asstt. Chief Water Analyst
DELHI JAL BOARD
Govt. of N.C.T. Delhi
Quality Control Laboratory
Water Works Nangloi, Delhi-41


BACT


A/CHEMIST

MUNICIPAL CORPORATION OF DELHI
(Office of Dy. Health Officer: Rohini Zone)
Public Health Department
Sector 5 Rohini Delhi -110085
Email: dhrohinizone15@gmail.com Tel: 011-27052106

No.-DHO/RZ/2024/ 999

Date : 15.03.2024


SCHOOL HEALTH CERTIFICATE

It is certified that an inspection team headed by Asst : Public health Inspector from Public Health department Rohini Zone inspected the **BALDEV INTERNATIONAL SCHOOL SITUATED AT KHASRA NO. 26/19/1/ (4-16) MAIN MUBARAKPUR ROAD, INDER ENCLAVE, NEW DELHI-110086**, and found that the **BALDEV INTERNATIONAL SCHOOL** has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus.

The above certificate is valid for the period of one year from the date of issue

BALDEV INTERNATIONAL SCHOOL
Khasra No. 26/19/1 (4-16), Main Mubarakpur
Road, Inder Enclave, New Delhi-110086

Dy. Health Office
Rohini Zone
Deputy Health Officer
Municipal Corporation of Delhi
Rohini Zone


BALDEV INTERNATIONAL SCHOOL
Kh. No. 26/19/1 (4-16)
Main Mubarak Pur Road, Inder Enclave
Phase-IV, New Delhi-110086